DNV·GI

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Object

Multi-core power cable

1036-17

Type

PVC/SWA/PVC/XLPE/mica/CU

Serial No.

Rated voltage, U₀/U (U_m)

0,6/1,0 (1,2) kV

Conductor material

Сп

Conductor cross-section

4x50+1x25 mm²

Insulation material

XLPE

Manufacturer

KEI Industries Ltd.,

SP-919, 920 & 922, Phase-III, RIICO Industrial Area,

Bhiwadi (Rajasthan), India *)

Client

KEI Industries Ltd.,

Rajasthan, India

Tested by

DNV GL Netherlands B.V.,

Arnhem, the Netherlands

Date of tests

20 December 2016 to 20 February 2017

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with the complete type test requirements of

IEC 60502-1 (2009)

subclauses 17 and 18

This Certificate has been issued by DNV GL following exclusively the STL Guides.

The results are shown in the record of proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5.

> This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

*) as declared by the manufacturer

This Certificate consists of 34 pages in total.

DNV GL Netberlands B.V.

Fonteijne

Executive Vice President KEMA Laboratories

Arnhem, 28 February 2017



.aboratories

INFORMATION SHEET

1 KEMA Type Test Certificate

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by DNV GL. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the equipment tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet.

The Certificate is applicable to the equipment tested only. DNV GL is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in DNV GL's Certification procedure applicable to KEMA Laboratories.

2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The report is applicable to the equipment tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silver-embossed lettering on the cover and a silver seal on its front sheet

The sentence on the front page of a KEMA Report of Performance will state that the tests have been carried out in accordance with The object has complied with the relevant requirements.

3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the test object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

4 Official and uncontrolled test documents

The official test documents of DNV GL are issued in bound form. Uncontrolled copies may be provided as loose sheets or as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

KEMA Laboratories

-3-

1036-17

TABLE OF CONTENTS

1	Identification of the test object	
1.1	Ratings/characteristics of the object tested	
1.2	Description of the test object	
1.3	List of documents	7
2	General information	8
2.1	The tests were witnessed by	8
2.2	The tests were carried out by	8
2.3	Subcontracting	8
2.4	Purpose of test	8
2.5	Measurement uncertainty	8
3	Conductor	<u>c</u>
3.1	Measurement of the resistance of the conductor	g
3.2	Measurement of the number of wires of the conductor	g
3.3	Measurement of the diameter of the conductor	g
4	Electrical type tests	10
4.1	Measurement of insulation resistance at ambient temperature	10
4.2	Measurement of insulation resistance at max. conductor temperature	11
4.3	Voltage test for 4 h	12
5	Non-electrical type tests	13
5.1	Measurement of thickness of insulation	13
5.2	Measurement of thickness of non-metallic sheaths	14
5.3	Tests for determining the mechanical properties of insulation before and after ageing	15
5.4	Tests for determining the mechanical properties of non-metallic sheaths before and	
	after ageing	16
5.5	Additional ageing test on pieces of completed cables	17
5.6	Loss of mass test on PVC sheaths of type ST ₂	18
5.7	Pressure test at high temperature on non-metallic sheaths	19
5.8	Test on PVC insulation and sheaths and halogen free sheaths at low temperatures	20
5.9	Test for resistance of PVC insulation and sheaths to cracking (heat shock test)	21
5.10	Hot set test for XLPE insulation	22
5.11	Water absorption test on insulation	23
5.12	Fire tests	24
5.12.1	Flame spread test on single cables	24
5.13	Shrinkage test for XLPE insulation	25
6	Verification of cable construction	26

KEMA	Laboratories -4-	1036-17
7	Additional tests	27
7.1	Tests on armour	27
7.1.1	Tensile strength and elongation	27
7.1.2	Torsion	27
7.1.3	Measurement of the diameter of steel armour wire	28
7.1.4	Measurement of the mass of zinc coating of galvanized steel wire	28
7.1.5	Measurement of the resistance of steel armour wire	28
7.2	Minimum thermal stability at 200 °C	29
7.3	Measuring the minimum oxygen concentration to support candle-like combustion	of
	plastics	30
7.4	Measuring the minimum temperature index	31
8	Drawing	32
9	Measurement uncertainties	34

1 IDENTIFICATION OF THE TEST OBJECT

1.1 Ratings/characteristics of the object tested

Rated voltage, U_0/U (U_m)

0,6/1,0 (1,2) kV

Rated maximum conductor temperature in normal operation

90 °C

Rated conductor cross-section

50+25 mm²

1.2 Description of the test object

Standard

IEC 60502-1:2004 +A1:2009

Manufacturer

KEI Industries Ltd., Rajasthan, India

Type

XLPE Cable

Manufacturing year

2016

Sampling procedure

by the manufacturer

Rated voltage, U₀/U

0,6/1,0 (1,2) V

No. of cores

5

Marking on the cable

KEI CABLE ELECRIC 0,6/1,0 (1,2) KV

4Cx50+Ex25 SQMM IEC 60502-1 XLPE/FR PVC

2016

Conductor

material

copper conductor, untinned

cross-section

main cores 50 mm² earth cores 25 mm²

main cores 8,7 mm

nominal diameter

earth cores 6,6 mm

tvpe

class 2, round compacted

number and nominal diameter of wires

main cores 7 x Ø 3,02 mm earth cores 7 x Ø 2,20 mm

maximum conductor temperature

90 °C

in normal operation

Insulation

XLPE

materialnominal thickness

main cores 1,00 mm

material designation

earth cores 0,90 mm

material supplier

known in KEMA Laboratories' files known in KEMA Laboratories' files

core identification

red / yellow / blue / black / yellow-green

KEMA Laboratories -6-1036-17 **Filler** material polypropylene **Binder** material polyester tape **Inner covering** PVC, ST₂ type PVC-ST-2 material 0,4 mm approximate thickness **Metallic armour** galvanized steel wire material 49 (approx) number of wires 2,0 mm nominal diameter / dimensions known in KEMA Laboratories' files material supplier **Oversheath** PVC, type ST₂ material 2,1 mm nominal thickness 41,0 mm outer diameter of cable PVC-ST-2 material designation known in KEMA Laboratories' files material supplier colour black Fire retardant yes Manufacturing details insulation system KEI Industries Ltd., location of manufacturing SP-919, 920 & 922, Phase-III, RIICO Industrial Area, Bhiwadi (Rajasthan), India VCV/HCV/MDCV/CCV factory identification of extrusion line type of extrusion triple common extrusion / triple extrusion long die known in KEMA Laboratories' files manufacturer of the extrusion line known in KEMA Laboratories' files identification of the production batch

manufacturing length (where cable sample for testing has been taken

length markings on cable sample

sent to KEMA Laboratories

from)

known in KEMA Laboratories' files

begin: 0000 m, end: 0063 m

1.3 List of documents

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawings and/or documents. KEMA Laboratories has verified that these drawings and/or documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawings and/or documents and the technical data presented.

The following drawings and/or documents have been included in this Certificate Drawing no./document no. Revision

Drawing no./document no. KEVDW/4C + E Sqmm

B C

2029203EL0018-000-EL-D09-00D1

2 GENERAL INFORMATION

2.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

2.2 The tests were carried out by

Name	Company				
B. Vos	DNV GL Netherlands B.V.,				
E.F. Rijpstra	Arnhem, the Netherlands				

2.3 Subcontracting

All tests were subcontracted to DNV GL – New Energy Technology, Arnhem, the Netherlands.

2.4 Purpose of test

Purpose of the test was to verify whether the material complies with the specified requirements.

2.5 Measurement uncertainty

A table with measurement uncertainties is enclosed in this Certificate Unless otherwise stated, the measurement uncertainties of the results presented in this Certificate are as indicated in that table.

3 CONDUCTOR

Standard and date

Standard

IEC 60502-1 clause 5

Test dates

20 and 21 December 2016

3.1 Measurement of the resistance of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Resistance main	Ω/km	≤ 0,387	0,387	0,387	0,387	-
Resistance earth	Ω/km	≤ 0,727	-	-	-	0,717

Result

The object passed the test.

3.2 Measurement of the number of wires of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Number of wires	-	≥ 6	7	7	7	7

Result

The object passed the test.

3.3 Measurement of the diameter of the conductor

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Diameter	mm	-	8,4	8,4	8,4	6,4

Result

The result is for information only.

4 ELECTRICAL TYPE TESTS

4.1 Measurement of insulation resistance at ambient temperature

Standard and date

Standard

IEC 60502-1, clause 17.1

Test dates

20 and 21 December 2016

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Volume resistivity, ρ						
at 20 °C	Ω .cm	-	7,16 ^E +15	3.62 ^E +15	8.9 ^E +15	1,8 ^E +16
Insulation resistance constant, K _i			7,16x10 ¹⁵	3,62x10 ¹⁵	8,9x10 ¹⁵	1,8x10 ¹⁵
at 20 °C	MΩ.km	_	26305	13306	32958	67773

Result

The test results are for information only.

4.2 Measurement of insulation resistance at max. conductor temperature

Standard and date

Standard

IEC 60502-1, clause 17.2

Test dates

20 and 21 December 2016

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Volume resistivity, ρ						
at 90 °C	$\Omega.cm$	≥ 10 ¹²	1,2 ^E +16	2,5 ^E +16	7,1 ^E +15	6,0 ^E +15
Insulation resistance constant, K _i			1,2x10 ¹⁶	2,5x10 ¹⁶	7,1x10 ¹⁵	6,0x10 ¹⁵
at 90 °C	MΩ.km	≥ 3,67	44627	94371	26101	22186

Result

4.3 Voltage test for 4 h

Standard and date

Standard

IEC 60502-1, clause 17.3

Test date

3 January 2017

Environmental conditions

Temperature

 20 ± 15 °C

Temperature of test object

20 °C

Applied voltage	Frequency	Duration	Measured/determined
kV	Hz	h	
2,4	50	4	No breakdown

Requirement

No breakdown of the insulation shall occur.

Result

5 NON-ELECTRICAL TYPE TESTS

5.1 Measurement of thickness of insulation

Standard and date

Standard

IEC 60502-1, clause 18.1

Test date

21 December 2016

Thickness	Unit	Requirement	Specified	Measured/determined			
				Red	Black	Blue	Green/yellow
Nominal main	mm	-	1,0	-	-	-	-
Average main	mm	≥ 1,0	-	1,7	1,2	1,6	-
Minimum (t _m) main	mm	≥ 0,80	 -	1,53	1,04	1,42	-
Nominal earth	mm	-	0,9	-	-	-	-
Average earth	mm	≥ 0,9	-	-	-	-	2,2
Minimum (t _m) earth	mm	≥ 0,71	-	-	-	-	2,00

Result

5.2 Measurement of thickness of non-metallic sheaths

Standard and date

Standard

IEC 60502-1, clause 18.2

Test date

21 December 2016

Oversheath

Thickness	Unit	Requirement	Specified	Measured/determined
Nominal	mm	≥ 1,8	2,1	-
Average	mm	-	-	2,6
Minimum (t _m)	mm	≥ 1,48	-	2,30

Result

5.3 Tests for determining the mechanical properties of insulation before and after ageing

Standard and date

Standard

IEC 60502-1, clause 18.3

Test dates

12 to 25 January 2017

Characteristic test data

Temperature during ageing

135 ± 3 °C

Ageing duration

7 days

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Without ageing						
Tensile strength	N/mm ²	≥ 12,5	23,1	18,2	24,1	22,3
Elongation at break	%	≥ 200	608	455	551	553
After ageing						
Tensile strength	N/mm²	-	24,8	17,4	25,8	25,1
Variation with samples without ageing	%	± 25 max.	7	-4	7	13
Elongation	%	-	565	420	533	573
Variation with samples without ageing	%	± 25 max.	-7	-8	-3	4

Result

5.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing

Standard and date

Standard

IEC 60502-1, clause 18.4

Test dates

12 to 23 January 2017

Characteristic test data (oversheath)

Temperature during ageing

100 ± 2 °C

Ageing duration

7 days

Oversheath

Oversileatii			
Item	Unit	Requirement	Measured/determined
Without ageing			
Tensile strength	N/mm ²	≥ 12,5	18,7
Elongation	%	≥ 150	214
After ageing			
Tensile strength	N/mm ²	≥ 12,5	19,8
Variation with samples without ageing	%	± 25 max.	6
Elongation	%	≥ 150	216
Variation with samples without ageing	%	± 25 max.	1

Result

5.5 Additional ageing test on pieces of completed cables

Standard and date

Standard

IEC 60502-1, clause 18.5

Test dates

12 to 25 January 2017

Characteristic test data

Temperature during ageing

100 ± 2 °C

Ageing duration

7 days

Insulation

Item	Unit	Requirement	Measur	Measured/determined		
			Red	Black	Blue	Green/yellow
Tensile strength	N/mm²	-	18,2	16,1	22,5	23,3
Variation with samples without ageing	%	± 25 max.	-21	-12	-7	4
Elongation	%	-	610	451	514	607
Variation with samples without ageing	%	± 25 max.	0	-1	-7	10

Oversheath

Item	Unit	Requirement	Measured/determined
Tensile strength	N/mm²	≥ 12,5	19,0
Variation with samples without ageing	%	± 25 max.	2
Elongation	%	≥ 150	227
Variation with samples without ageing	%	± 25 max.	6

Result

5.6 Loss of mass test on PVC sheaths of type ST₂

Standard and date

Standard

IEC 60502-1, clause 18.6

Test dates

4 January 2017

Characteristic test data

Temperature during ageing

100 ± 2 °C

Duration

7 days

Oversheath

Item	Unit	Requirement	Measured/determined
Loss of mass	mg/cm ²	≤ 1,5	1,1

Result

5.7 Pressure test at high temperature on non-metallic sheaths

Standard and date

Standard

IEC 60502-1, clause 18.7

Test date

9 January 2017

Characteristic test data (oversheath)

Temperature during ageing 90 \pm 2 °C Duration 6 h Load 8 N

Oversheath

o v el				
Item	Unit	Requirement	Measured/determined	
Depth of indentation	%	≤ 50	26	

Result

5.8 Test on PVC insulation and sheaths and halogen free sheaths at low temperatures

Standard and date

Standard

IEC 60502-1, clause 18.8

Test dates

9 and 10 January 2017

Characteristic test data (oversheath)

Temperature

 -15 ± 2 °C

Period of application

>16 h

Mass of hammer

1000 g

Oversheath

Item	Unit	Requirement	Measured/determined
Cold elongation	%	≥ 20	76
Cold impact test	_	No cracks	No cracks

Result

5.9 Test for resistance of PVC insulation and sheaths to cracking (heat shock test)

Standard and date

Standard

IEC 60502-1, clause 18.9

Test date

11 January 2017

Characteristic test data (oversheath)

Temperature 150 ± 3 °C Period of application 1 h Diameter of mandrel 6 mm Number of turns 6 mm

Oversheath

Item	Unit	Requirement	Measured/determined
Soundness	-	No cracks	No cracks

Result

5.10 Hot set test for XLPE insulation

Standard and date

Standard

IEC 60502-1, clause 18.11

Test date

12 January 2017

Characteristic test data

Temperature

200 ± 3 °C

Time under load

15 min

Mechanical stress

20 N/cm²

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Elongation under load	%	≤ 175	73	70	76	78
Permanent elongation	%	≤ 15	4	5	5	6

Result

-23-

1036-17

5.11 Water absorption test on insulation

Standard and date

Standard

IEC 60502-1, clause 18.13

Test dates

15 December 2016 to 5 January 2017

Characteristic test data

Temperature

85 ± 2 °C

Duration

14 days

Item	Unit	Requirement	Measure	d/determin	ed	
			Red	Black	Blue	Green/yellow
Variation of mass	mg/cm ²	≤ 1	0,08	0,06	0,05	0,07

Result

5.12 Fire tests

5.12.1 Flame spread test on single cables

Standard and date

Standard

IEC 60502-1, clause 18.14.1

Test date

30 January 2017

Characteristic test data

Duration

120 s

Item	Unit	Requirement	Measured/determined
Length free of charring	mm	> 50	470
Downward limit charred surface	mm	< 540	481

Result

5.13 Shrinkage test for XLPE insulation

Standard and date

Standard

IEC 60502-1, clause 18.16

Test date

12 January 2017

Characteristic test data

Temperature

130 ± 3 °C

Duration

1 h

Item	Unit	Requirement	Measured/determined			
			Red	Black	Blue	Green/yellow
Shrinkage	%	≤ 4	1,5	3	1,5	1,5

Result

6 VERIFICATION OF CABLE CONSTRUCTION

Verification of cable construction was carried out in accordance with clauses 5-13 of IEC 60502-1. The results are presented below.

	Observed/determined			
Marking on the cable	KEI CABLE ELECTRIC 0,6/1 kV (1,2 Kv) 4Cx50+Ex25 SQMM IEC 60502-1 XLPE/FR PVC 2016			
Construction	Copper conductor compacted class 2 main core 1-6 Ø 3,02 earth core 1-6 Ø 2,20			
	Mica tape double layer			
	XLPE insulation			
	Polypropylene filler			
	Synthetic binder tape and cord			
	Inner covering, type ST2			
	Steel wire armour 49 st Ø 2,0 approx.			
	Outer sheath, type ST2			
Outer diameter of the cable, average	43,5 mm approx.			
Outer diameter of the cores, average	Red: 12,0 mm approx. Black: 12,0 mm approx. Blue: 12,0 mm approx. Green/yellow: 12,0 mm approx.			

Result

No significant deviations from the specified requirements are found.

7 ADDITIONAL TESTS

7.1 Tests on armour

Standard and date

Standard

EN 10257-1

Test dates

4 January to 20 February 2017

7.1.1 Tensile strength and elongation

Characteristic test data

Speed tensile test

250 mm/s

Diameter of wires

2,0 mm

Amount of tested wires

5

Item	Unit	Requirement	Measured/determined
Tensile strength	N/mm²	$340 \le F \le 500$	442
Elongation	%	≥ 10	15 (mean)
Variation within one batch	N/mm²	≤ 150	93

Result

The object passed the test.

7.1.2 Torsion

Characteristic test data

Gauge length

150 mm

Diameter of wires

2,0 mm

Amount tested wires

5

Item	Unit	Requirement	Measured/determined
Minimum number of turns	-	≥ 30	44

Result

7.1.3 Measurement of the diameter of steel armour wire

Item	Unit	Requirement	Measured/determined
Diameter	mm	$1,9950 \le d \le 2,0050$	2,0000 (mean)

Result

The object passed the test.

7.1.4 Measurement of the mass of zinc coating of galvanized steel wire

Item	Unit	Requirement	Measured/determined
Mass of zinc	g/m²	≥ 155	162

Result

The object passed the test.

7.1.5 Measurement of the resistance of steel armour wire

Item	Unit	Requirement	Measured/determined
Resistance	Ω/km	≤ 43,93	0,78

Result

7.2 Minimum thermal stability at 200 °C

Standard and date

Standard IEC 60811-405
Test date 6 February 2017

Characteristic test data

Temperature 200 ± 0.5 °C Number of samples 3 Weight of sample 50 ± 5 mg Change in pH-value 5 to 3

 Item
 Unit
 Requirement
 Measured/determined

 Thermal stability
 min
 ≥ 100
 168

Result

7.3 Measuring the minimum oxygen concentration to support candle-like combustion of plastics

Standard and date

Standard ASTM D 2863 Test date 9 February 2017

Characteristic test data

Temperature during test 22 °C

Dimensions 1,85 mm x 10 mm x 100 mm (type III)

Gas measurement accuracy 0,1%

Ignition procedure Top surface ignition (method A)

Oversheath

Item	Unit	Requirement	Measured/determined
As received			
Oxygen Index*	%	≥ 28	Approx.30,5 (charring behaviour)

^{*} Measuring the minimum oxygen concentration to support candle-like combustion of plastics (Oxygen index)

Note

The test results relate only to the behaviour of the test specimens under the conditions of this test method and these results may not be used to infer the fire hazards of the material in other forms or under other fire conditions.

Result

7.4 Measuring the minimum temperature index

Standard and date

Standard

Client's instructions

Test date

14 February 2017

Characteristic test data

Temperature during test

22 °C

Dimensions

1,85 mm x 10 mm x 100 mm (type III)

Gas measurement accuracy

0,1%

Ignition procedure

Top surface ignition (method A)

Oversheath

Item	Unit	Requirement	Calculated
As received			
Oxygen Index*	%	≥ 21	Approx.25% at 250 °C

^{*} Measuring the minimum oxygen concentration to support candle-like combustion of plastics (Oxygen index)

Note

The result was calculated by instruction of the client. Multiple measurements at 25, 50, 75, 100, 125 °C where carried out and the oxygen index at 250 °C was extrapolated.

The test results relate only to the behaviour of the test specimens under the conditions of this test method and these results may not be used to infer the fire hazards of the material in other forms or under other fire conditions.


Result

The object passed the test as per client's requirements.


8 DRAWING

Page No. 11 of 16

Rev.No.:- B



as per IEC 60502-1




CABLE DETAILS

- 1. Conductor Stranded (Class 2) Annealed Plain Copper
- 2. Mica Glass Tape
- 3.Insulation Cross Linked polyethylene (XLPE)
- 4.Inner Sheath Extruded PVC Type ST-2 Compound
- 5.Armour Galvanized Steel Round Wire
- 6. Outer Sheath Extruded Flame Retardant PVC Type ST-2 Compound

KEI Industries Ltd, India

Drawing No. - KEI/DWG/4C+E Sqmm

Not to Scale



9 MEASUREMENT UNCERTAINTIES

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Tensile strength test	1%
Measurement of dimensions	5 μm
Measurement loss of mass	0,11 mg : 8,0 gr
Measurement of conductor resistance	0,03% of measured value
Measurement at low temperature	0,1 °c
Measurement in heating cabinets	0,1 °c
Voltage test	2.10 ⁻³ .u + 20v 2.10 ⁻³ .i + 0,2%