



Technická inšpekcia, a.s.

Trnavská cesta 56, 821 01 Bratislava
Slovenská republika

CERTIFICATE No.: 2355/1/2021

to technical file of equipment issued according of EN ISO/IEC 17020

Date of issue: **5th August 2021**

Name of equipment: **Flexible PVC Insulated Wires And Cables**

Type designation: **Flexible Unarmoured Wires And Cables**

Rated Voltage: 300/500V and 450/750V

Cross – sectional area: 0,5 Sqmm to 240 Sqmm

Shape of conductor: Circular (Class-5)

Material: Plain Annealed Copper Conductor As per IEC:60228

Construction: Conductor Number of conductors: 2,3,4,5

Manufacturer: **KEI INDUSTRIES LTD.
99/27, MADHUBAN INDUSTRIAL ESTATE, VILLAGE RAKHOLI,
SILVASSA, DADRA AND NAGAR HAVELI AND DAMAN AND DIU –396230
INDIA**

Applicant: **See manufacturer**


Basis for certificate issuing: Inspection report No: 2355/1/2021

Applicable standards: IEC-60227-1, IEC 60227-2, IEC 60227-3, IEC 60227-5 & IEC 60228

After evaluation of submitted documentation of equipment (TCF) in accordance with Directive 2014/35/EU, Technická inšpekcia, a. s. issues this

certificate

the technical file of equipment fulfills safety requirements and it is in accordance with Low Voltage Directive 2014/35/EU.

The manufacturer may indicate compliance to this directive by signing EU declaration of conformity himself according Article 15 of this directive and applying the CE marking  to the equipment according Article 16 and 17 of this directive.


The manufacturer will inform Technická inšpekcia, a. s. about every modification that can affect safety of the equipment.


This certificate is valid to 5th August 2024

Bratislava 5th August 2021



On behalf of Technická inšpekcia, a. s.


JUDr. Vladimír Jurík
General Director

INDIA Representative:  TARGET CONFORMITY MANAGEMENT SERVICES, For any questions use www.tcmservices.net

453835
CERT11-056