

TYPE APPROVAL CERTIFICATE

Certificate no.:
TAE00003U6
Revision No:
1

This is to certify:

that the **Electric Power Cable**

with type designation(s)
P105 BFOU H-M, BFCU, BFOU VFD,

issued to

KEI Industries Limited
Mumbai, Maharashtra, India

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (kV)	Temp. class (°C)
P105 BFOU H-M	0,6/1	90
BFCU	0,6/1	90
BFOU VFD	0,6/1	90

Issued at **Hamburg** on **2025-03-14**

This Certificate is valid until **2030-03-13**.

DNV local unit: **Mumbai NB & CMC**

Approval Engineer: **Carsten Hunsalz**



for **DNV**

This document has been digitally signed and will
therefore not have handwritten signature

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Type: P105 BFOU H-M, BFCU, BFOU-VFD

Construction:

Conductors: Tinned stranded copper class 2 or class 5

Core Insulation: Mica tape + EPR

Filler: Extruded SHF1

Metal covering: Tinned copper wire braid (O) or
Galvanised steel wire braid (C) for multicore cables only
Additional copper taped screen for Type BFOU-VFD

Outer sheath: SHF2 or SHF Oil and Mud

P105 BFOU H-M, BFCU

Number of cores x conductor cross- section mm ²
1 x 10
1 x 16
1 x 25
1 x 35
1 x 50
1 x 70
1 x 95
1 x 120
1 x 150
1 x 185
1 x 240
1 x 300
1 x 400
1 x 500
1 x 630
1 x 800
1 x 1000
2 x 1,5 / 7
2 x 2,5 / 7
2 x 4 / 8
2 x 6 / 8
2 x 10 / 10
2 x 16 / 16
2 x 25 / 16
3 x 1,5 / 7
3 x 2,5 / 7
3 x 4 / 8
3 x 6 / 9
3 x 10 / 10
3 x 16 / 16
3 x 25 / 16
3 x 35 / 17.5
3 x 50 / 25

Number of cores x conductor cross- section mm ²
3 x 70 / 35
3 x 95 / 47.5
3 x 120 / 60
3 x 150 / 75
3 x 185 / 95
3 x 240 / 120
3C+E X 2.5
3C+E X 4
3C+E X 6
3C+E X 10
3C+E X 16
3C+E X 25
3C+E X 35
3C+E X 50
3C+E X 70
3C+E X 95
3C+E X 120
3C+E X 150
3C+E X 185
3C+E X 240
4 x 1,5 / 7
4 x 2,5 / 8
4 x 4 / 9
4 x 6 / 9
4 x 10 / 10
4 x 16 / 16
4 x 25 / 16
4 x 35 / 17.5
4 x 50 / 25
4 x 70 / 35
4 x 95 / 47.5
4 x 120 / 60

Number of cores x conductor cross- section mm ²
4 x 150 / 75
4 x 240 / 120
5 x 1,5 / 6
5 x 2,5 / 6
7 x 1,5 / 9
7 x 2,5 / 10
12 x 1,5 / 12
12 x 2,5 / 13
19 x 1,5 / 13
19 x 2,5 / 14
27 x 1,5 / 16
27 x 2,5 / 19
37 x 1,5 / 25
37 x 2,5 / 30
BFCU
2CX1.5
2CX2.5
2CX4
2CX6
2CX10
2CX16
2CX25
2CX50
2CX70
2CX95
2CX120
3CX1.5
3CX2.5
3CX4
3CX6
3CX10

Number of cores x conductor cross- section mm ²
3CX16
3CX25
3CX35
3CX50
3CX70
3CX95
3CX240
4CX1.5
4CX 2.5
4CX4
4CX6
4CX10
4CX16
4CX25
4CX35
4CX50
4CX70
4CX95
5CX2.5
7C x 1.5
7CX2.5
8C x 2.5
12CX1.5
12CX2.5
14C x 2.5
19CX1.5
19CX2.5
21C x 1.5
27CX1.5
27CX2.5
37CX1.5
37CX2.5

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

General power and lighting.

Fire resistant. Flame retardant in bunch Cat. A. Halogen free. Low smoke.

Oil and Mud resistant, Category d with Hydraulic/gear oil PARTHAN EP No.320 / ENKLO No.68

Type Approval documentation

Data sheets: KEI BFOU P5/P12 0,6/1 and BFCU 0,6/1 kV and BFOU VFD 0,6/1kV dated 2009-09-10
KEI/19/DNV DATED: 08 March 2019

Test reports KEI BFOU P5/P12 0,6/1 and BFCU 0,6/1 kV BFOU VFD 0,6/1kV dated 2010-06-02
KEI DNV/19/IT/01 dated 2019-09-04/05/13/20 and 2019-11-02 and 2019-06-10

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2024-06	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60331-1	2018-03	Tests for electric cables under fire conditions - Circuit integrity - Part 1: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV	Minimum 120 min. For cables with an overall diameter exceeding 20 mm
IEC 60331-2	2018-03	Tests for electric cables under fire conditions - Circuit integrity - Part 2: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV	Minimum 120 min. For cables with an overall diameter not exceeding 20 mm
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	Fluorine content < 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Standard	Release	General description	Limitation
NEK TS 606	2022	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	P-types only, Mud resistance test: IRM902+IRM903 100°C 7d. Calcium Bromide 70°C 56d. <u>Oil based mud:</u> Carbo Sea 70°C 56d or EDC 95/11 70°C 56d <u>Hydraulic/gear oil:</u> PARTHAN EP No.320 / ENKLO No.68 100°C 7d.

Marking of product

KEI – P105 BFOU H-M or BFCU or BFOU-VFD – size - 0,6/1 kV - IEC 60331-1/2 - IEC 60332-3-22 Cat A
 - Year

Place of Production

KEI Industries Limited, SP-919,920 & 922, Riico Industrial Area, Phase-III, Bhiwadi, Rajasthan-301019, INDIA.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE